



WATERITE TECHNOLOGIES, INC.  
3-75 Meridian Drive  
Winnipeg, MB  
Canada R2R 2V9  
(204) 786-1604  
fax (204) 783-1599  
waterite@waterite.com  
www.waterite.com

## Compliance Certification For *ExcelPlus+™* One Micron Absolute Rated Pleated Filter Cartridges

### Cryptosporidium and Giardia reduction

This is to certify *ExcelPlus+™* one micron absolute rated pleated filter cartridges meet or exceed the three log (99.9%) removal requirements described in NSF Standard 53 for cyst-sized particles.

Efficiency tests were performed by HML Laboratory, located in Muncie, Indiana, using EPA method 1623, entitled "*Cryptosporidium and Giardia in Water by Filtration / IMS / FA, With A Variation*".

All tests were performed in triplicate, along with a positive and negative control. Actual Cryptosporidium oocysts and Giardia cysts were used to perform all tests.

Efficiency was >99.9% removal of both Cryptosporidium oocysts and Giardia cysts.

### FDA

It is further certified all *ExcelPlus+™* filter media are FDA grade, with raw materials FDA listed for use in potable water and liquid food applications.

For more information and formal test results, please contact Waterite at:

Waterite Technologies, Inc.  
3-75 Meridian Drive  
Winnipeg, MB  
Canada R2R 2V9  
(204) 786-1604  
Waterite@waterite.com

